

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

AI179
South
1/4-1/2
0.316 mi.
1667 ft.

TRANSFORMER MANHOLE 1060
SURF AVE & W 12TH STREET
BROOKLYN, NY

NY Spills S106014058
N/A

Site 1 of 8 in cluster AI

Relative:
Higher

SPILLS:

Actual:
6 ft.

Name: TRANSFORMER MANHOLE 1060
Address: SURF AVE & W 12TH STREET
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 0301639 / 2003-06-17
Facility ID: 0301639
Facility Type: ER
DER Facility ID: 250840
Site ID: 310770
DEC Region: 2
Spill Cause: Unknown
Spill Class: C4
SWIS: 2401
Spill Date: 2003-05-14
Investigator: KMFOLEY
Referred To: Not reported
Reported to Dept: 2003-05-15
CID: 422
Water Affected: Not reported
Spill Source: Unknown
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False

UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2003-05-15
Spill Record Last Update: 2003-06-17
Spiller Name: UNKNOWN
Spiller Company: UNKNOWN
Spiller Address: Not reported
Spiller Company: 001
Contact Name: KEVIN MCARDLE
DEC Memo: "Prior to Sept, 2004 data translation this spill Lead_DEC Field was FOLEY Con Ed e2mis #148355: 5-14-03 1630 HRS K. DAVIS # 16852 SPLICER NETWORK REPORTS WHILE GETTING READY TO REBAGGE STRUCTURE FROM FDR. 7B44 TO FDR. 11B04 IN TM1060 N/S SURF AVE 232' E/O W.12 ST HE FOUND APPROX 1 GALLON UNKNOWN OIL ON 3000 GALLONS WATER. HISTORICAL RECORD OF TRANSF IS 0 PPM AND WAS LAST TESTED 11-01-2000 . HE PRESSURE TESTED UNIT AND IT TESTED GOOD (HELD PRESSURE) HE ALSO CHECK OIL LEVEL (IT WAS GOOD) . HE TOOK A LIQUID SAMPLE AND REQUESTED EMERG PRIORITY FOR PCB SAMPLE RESULTS. CLEANUP PENDING SAMPLE RESULT. CHAIN OF CUSTODY # CC16734. HE PLACED E.S. TAG # 34092. 5-14-03 23:43HRS LAB SEQ# 03-04030-001 70 PPM. 5-15-03 00:10HRS OVER TANKER ORDERED FOR TNE MORNING. 5-15-03 01:05HRS EPA NYP 004 111 118. UPDATE @ 1210 HRS 5/15 T.FENANDEZ SUP ENVIROMENATL OPS REPORTS CALLING CLEAN VENTURES TO CONTINUE CLEANUP FOUND TOO MUCH WATER IN STRUCTURE FOR CORP TANKED STRUCTURE ALSO CONTAINS MUD & DEBRIS. 5/15/03 2130hrs TM1050 was cleaned out utilizing Env Ops cerw and Clean Ventures truck. 1850gal of liquid was removed by an Astoria tanker. Clean Ventures truck took 2742kg of debris under New Jersey manifest #NJA4116380. Structure was double washed using 15gal of biogen 760. 1 drum filled with PPE and site setup was brought back to 3rd Ave Yard under one trip rule using

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

Remarks: tracking form#215610."
"no the 5's "

All Materials:

Site ID: 310770
Operable Unit ID: 869654
Operable Unit: 01
Material ID: 506132
Material Code: 0066A
Material Name: unknown petroleum
Case No.: Not reported
Material FA: Petroleum
Quantity: 1.00
Units: G
Recovered: .00
Oxygenate: Not reported